



WICHITA, KANSAS

ADDENDUM NO. 4
TO THE Bid 203112

Hess Pump Station Valve Replacement
(1401 West Museum Boulevard)

448-90958 W9004

TO BE BID: May 1, 2020

The following changes and additions shall be made to the plans and proposal.

1. **BID FORM ITEM #6: REVISE** Section 1 – Pump Isolation Valves bid item “Coupling Replacement, 30”” is reduced to 20 each.

CLARIFICATION There is only one coupling adjacent to the pump discharge valve of Pump 7.

2. **BID FORM ITEM #11: REVISE** Section 2 – Discharge Header Valves bid item “Coupling Replacement, 48”” is reduced to 12 each.

CLARIFICATION There is one coupling replaced adjacent to each discharge header valve.

3. **SUPPLEMENTAL PROVISIONS – SECTION 33 12 16 VALVES AND APPURTENANCES: ADD** the following paragraph to Sections 2.2.C.1 and to 2.3.C.1:

c. Limit switches shall be provided with manual operators. Limit switch shall be either a lever style or a rotary style switch. The switches shall be double-pole, double-throw (DPDT).

4. **SUPPLEMENTAL PROVISIONS – SECTION 33 12 16 VALVES AND APPURTENANCES:**

CLARIFICATION The threaded studs and nuts shall be Corten material per the City of Wichita Standard Specifications.

Each bidder is required to acknowledge receipt of this Addendum by his signature affixed hereto and to file same with and attached to his bid. Any Bid Proposal that is returned without all addenda signed and included in the Proposal shall be considered an invalid Proposal.

April 28, 2020

Gary Janzen, P.E.
City Engineer

Date _____

Signature of Bidder

BIDDER: _____
(print or type name of firm)

ADDRESS: _____

AUTHORIZED AGENT: _____
(Signature)

(print or type name of authorized agent)