



TRAFFIC ENGINEERING
DIVISION APPROVED
Off Street Parking
Spaces Shown *Approved*
Date *5-11-67* *W. S. Hayes*

NOTICE
 (1) Parking barriers shall be installed at all locations that are adjacent to public property so that vehicles will not obstruct public property and have a minimum length of 6 feet and a minimum cross section of 4" x 4".
 (2) All painted stall lines shall be not less than 4" wide.
 (3) Proper ingress and egress signs shall be installed on private property at the entrances and exits of the parking facility.
 (4) Notify Traffic Engineering Division (AM 2-8211, Ext. 274) for final inspection of parking facility.

A I I A

FEARNSHIP
ARCHITECTS
INCORPORATED
1000 W. 10th St.
MILWAUKEE, WISCONSIN

DUDY REFINING CO.

SERVICE DIVISION
TRAFFIC ENGINEERING
21st Street
MILWAUKEE, WISCONSIN

REVISION

DRAWN BY
DICK GETTO

CHECKED BY

DATE
4 May 1967

JOB NO.
11-1009

SHEET NO.
II

OF ONE

B7A18-67