

find tracing received  
3-6-01

I, Jim E. Bishop, Land Surveyor in the State of Kansas, do hereby certify that I have surveyed and platted "STRUTHERS CREEK", Sedgwick County, Kansas, and that the accompanying plat is a true and correct exhibit of said survey described as follows: Commencing at the NE corner of Section 27, T29S, R3W of the 6th P.M., Sedgwick County, Kansas; thence S90°00'W along the north line of the E 1/2 of said Section 27, 25.35 feet to a point of beginning, said point being on the northwesterly right of way of K-42 Highway; thence S57°12'00"W along said northwesterly right of way, 731.18 feet to a point of curve; thence continuing on said northwesterly right of way, southwesterly on a curve to the right having a radius of 11,399.19 feet, a distance of 804.99 feet; (said point being described as 1532.55 feet from the north line of said E 1/2); thence N79°14'26"W, 469.31 feet, (467.6 feet described); thence S11°14'24"W, 414.98 feet, (414.9 feet described); thence S64°27'03"E, 142.4 feet to the northwesterly right of way of said K-42 Highway, (142 feet described); thence southwesterly along said northwesterly right of way, on a curve to the right having a radius of 11,399.19 feet, a distance of 169.18 feet to a point of tangent; thence S44°17'00"W along said northwesterly right of way, 884.29 feet to the west line of said E 1/2 of said Section 27, thence N00°00'22"E along the west line of said E 1/2 of said Section 27, 884.02 feet; thence N72°38'14"E, 457.83 feet; thence S70°29'17"E, 139.23 feet; thence N63°54'43"E, 564.9 feet; thence N1° 19'55"W, 533.05 feet; thence N26°47'41"E, 131.29 feet; thence N59°47'24"E, 363.16 feet; thence N10°39'08"E, 267.39 feet; thence N30°08"E, 205.33 feet; thence N32°27'27"W, 440.77 feet to the north line of said E 1/2 of said Section 27; thence N90°00'E along the north line of said E 1/2 of said Section 27, 1,090.98 feet to the point of beginning.

Know all men by these presents that we, John W. Struthers, Trustee of the John W. Struthers Revocable Trust Dated April 25, 1996 and Lola F. Struthers, Trustee of the Lola F. Struthers Revocable Trust Dated April 25, 1996, as joint tenants, have caused the land described in the Land Surveyor's certificate to be platted into lots to be known as "STRUTHERS CREEK", Sedgewick County, Kansas. Utility easements as indicated on the plat are hereby granted for the construction and maintenance of all public utilities.

The Floodway Reserve is hereby granted for drainage purposes. No building shall be constructed on or within said Floodway Reserve; nor shall any fill, change of grade, creation of channel or other work be carried on without the permission of the appropriate governing body, with such permission of said appropriate governing body, additional improvements and/or activities may be permitted within said Floodway Reserve.

All abutter's rights of access to or from K-42 Highway, over and across the easterly line of Lot 1, are hereby granted to the appropriate governing body.

The Minimum Building Pad Elevations for the lowest opening to the structures shall be as indicated on the face of the plat.


The foregoing instrument was acknowledged before me this \_\_\_\_ day of \_\_\_\_\_, 2001 by John W. Struthers, Trustee of the John W. Struthers Revocable Trust Dated April 25, 1996 and Lola F. Struthers, Trustee of the Lola F. Struthers Revocable Trust Dated April 25, 1996, as joint tenants.

My Commission Expires: \_\_\_\_\_

Dated this \_\_\_\_\_ day of \_\_\_\_\_, 2000.

\_\_\_\_\_, Chairman  
Francis S. Garofalo

B.M. - Elev. 1301.64 = U.S.G.S. standard disc.  
144' NE of the NE cor.  
of Section 27, T29S, R3W.





**Wichita-Sedgwick County Metropolitan Area Planning Department**

June 29, 2000

Jim Bishop  
Sandalwood Surveying, Inc.  
P.O. Box 75053  
Wichita, KS 67275-5053

RE: S/D 00-17 -- Final Plat of STRUTHERS CREEK ADDITION

At the regular meeting of the Metropolitan Area Planning Commission on June 29, 2000, the above captioned plat was considered. The action of the Planning Commission was to recommend that the plat be approved as recommended by the Subdivision Committee subject to the conditions stated in our letter of June 23, 2000.

In addition to complying with those conditions, it is necessary that you meet the following requirements before this plat can be forwarded to the City Council and/or County Commission for consideration:

1. Submission of the fully completed and signed tracing of the subdivision, along with four (4) copies, to the Metropolitan Area Planning Department.
2. Submission of a check, made out to the Register of Deeds, covering the costs of any documents to be recorded as a requirement of platting.
3. Subdivision regulations now require a detailed Lot Grading Plan be submitted to Engineering prior to the tracing being released. This applies to all multi-lot, residential developments.
4. Submission of a disk to the Planning Department detailing the final plat in digital format in Autocad. This will be used by the City and County GIS Departments.

If you have any questions concerning this matter, please call.

Sincerely,

A handwritten signature in cursive script that reads 'Neil Evan Strahl'.

Neil Evan Strahl, Senior Planner  
Current Plans Division

City Hall • 10th Floor • 455 North Main • Wichita, Kansas 67202-1688

T 316.268.4421 F 316.268.4390

[www.wichitagov.org](http://www.wichitagov.org)



**Wichita-Sedgwick County Metropolitan Area Planning Department**

June 23, 2000

Jim Bishop  
Sandalwood Surveying, Inc.  
P.O. Box 75053  
Wichita, KS 67275-5053

RE: S/D 00-17 -- Final Plat of STRUTHERS CREEK ADDITION

At the regular meeting of the Subdivision Committee of the Metropolitan Area Planning Commission on Thursday, June 22, 2000, the above captioned plat was considered. The action of the Committee was to approve the final plat, subject to:

**STAFF COMMENTS:**

- A. Since neither municipal water nor sanitary sewer is available to serve this property, the applicant shall contact the Environmental Health Division of the **Health Department** to find out what tests may be necessary and what standards are to be met for approval of on-site sewerage facilities and water wells. A memorandum shall be obtained specifying approval. **A lot layout is required to be submitted for Lot 4. Additional soil testing is required.**
- B. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning department for recording.
- C. **County Engineering** needs to comment on the status of the applicant's drainage plan. **The drainage plan is approved. Minimum pad elevations have been determined based on the HEC-2 Run - 1298 (Lot 1), 1298 (Lot 2), 1299 (Lot 3), and 1305 (Lot 4). A Letter of Map Amendment (LOMA) needs to be provided before release of the plat for recording.**
- D. The applicant has platted one opening along 103rd St. South, and two openings along K-42. **County Engineering** and **KDOT** need to comment on the access controls. **KDOT has approved two openings along K-42. County Engineering has required complete access control along the east 200 feet of the plat's frontage to 103<sup>rd</sup> St. South and one opening along the remaining frontage.**
- E. The joint access opening between Lots 2 and 3 needs to be established by separate instrument.

- F. County Surveying has advised that the plat boundary does not close.
- G. The Applicant is reminded that a platting binder is required with the final plat. Approval of this plat will be subject to submittal of this binder and any relevant conditions found by such a review.
- H. If platted, the building setback may be a minimum of 30 feet to conform with the RR District zoning standards.
- I. Thomas G. Winters shall be indicated as the Chairman of the County Commissioners.
- J. "Tricia L. Robello, LS #1246" shall be indicated as the Deputy County Surveyor.
- K. Francis S. Garofalo shall be indicated as the Chairman of the Planning Commission.
- L. Marvin S. Krout shall be indicated as the Secretary of the Planning Commission.
- M. The plat's text shall delete the language referencing the dedication to the appropriate governing body of the access easement between Lots 2 and 3.
- N. The plat's text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.
- O. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- P. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- Q. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (phone 316-729-0102) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- R. The applicant is advised that various State and Federal requirements [specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147] for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- S. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.

S/D 00-17 -- Final Plat of STRUTHERS CREEK ADDITION

June 22, 2000

Page 3

- T. Perimeter closure computations shall be submitted with the final plat tracing.
- U. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.
- V. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.
- W. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in AutoCAD. This will be used by the City and County GIS Department.

If this plat requires the guaranteeing of improvements a list of the five methods which have been adopted as being acceptable is available through the Planning Department. Certificates, which are required if petitions are submitted, and forms for the Bond and Irrevocable Letter of Credit are available from this office.

This matter will be forwarded to the Planning Commission for its consideration on Thursday, June 29, 2000, at 1:15 p.m.

The enclosed "marked" copy of the plat is for your information and files.

If you have any questions concerning this matter, please call.

Sincerely,



Neil Evan Strahl, Senior Planner  
Current Plans Division

NES:ch

Enclosure: Marked Copy of Plat

Copies to: John Struthers, C/O Wesley Struthers, 7741 S. 119<sup>th</sup> Street West, Clearwater, KS 67026  
Mike Lindebak, City Engineering, Mail Stop (1-71)  
Jim Weber, PE-Director, Sewer Operations & Maintenance Department, Bureau of Public Services, 1144 S. Seneca, Wichita, KS 67213

**STAFF REPORT**

(Final Plat Approved 6/22/00; Preliminary Plat Approved 2/17/00)

**CASE NUMBER:** S/D 00-17 -- STRUTHERS CREEK ADDITION

**OWNER/APPLICANT:** John Struthers, C/O Wesley Struthers, 7741 S. 119<sup>th</sup> Street West, Clearwater, KS 67026

**SURVEYOR/ENGINEER:** Sandalwood Surveying, Attn: Jim Bishop, P.O. Box 75053, Wichita, KS 67275-5053

**LOCATION:** South side of 103<sup>rd</sup> Street South, West of 247<sup>th</sup> Street West

**SITE SIZE:** 35.9 Acres


**NUMBER OF LOTS**

|              |   |
|--------------|---|
| Residential: | 4 |
| Office:      |   |
| Commercial:  |   |
| Industrial:  |   |
| Total:       | 4 |

**MINIMUM LOT AREA:** 6.4 Acres

**CURRENT ZONING:** RR, Rural Residential

**PROPOSED ZONING:** Same

**VICINITY MAP**

**Note:** This site is located in the County in an area designated as "agricultural" by the Wichita-Sedgwick County Comprehensive Plan. It is within the 100 year floodplain.

**STAFF COMMENTS:**

- A. Since neither municipal water nor sanitary sewer is available to serve this property, the applicant shall contact the Environmental Health Division of the Health Department to find out what tests may be necessary and what standards are to be met for approval of on-site sewerage facilities and water wells. A memorandum shall be obtained specifying approval.  
*A lot layout is required to be submitted for Lot 4. Additional soil testing is required.*
- B. If improvements are guaranteed by petition, a notarized certificate listing the petitions shall be submitted to the Planning department for recording.
- C. County Engineering needs to comment on the status of the applicant's drainage plan. *The drainage plan is approved. Minimum pad elevations have been determined based on the HEC-2 Run - 1298 (Lot 1), 1298 (Lot 2), 1299 (Lot 3), and 1305 (Lot 4). A Letter of Map Amendment (LOMA) needs to be provided before release of the plat for recording.*
- D. The applicant has platted one opening along 103rd Street South, and two openings along K-42. County Engineering and KDOT need to comment on the access controls. *KDOT has approved two openings along K-42. County Engineering has required complete access control along the east 200 feet of the plat's frontage to 103<sup>d</sup> Street South and one opening along the remaining frontage.*
- E. The joint access opening between Lots 2 and 3 needs to be established by separate instrument.
- F. County Surveying has advised that the plat boundary does not close.
- G. The Applicant is reminded that a platting binder is required with the final plat. Approval of this plat will be subject to submittal of this binder and any relevant conditions found by such a review.
- H. If platted, the building setback may be a minimum of 30 feet to conform with the RR District zoning standards.
- I. Thomas G. Winters shall be indicated as the Chairman of the County Commissioners.
- J. "Tricia L. Robello, LS #1246" shall be indicated as the Deputy County Surveyor.
- K. Francis S. Garofalo shall be indicated as the Chairman of the Planning Commission.
- L. Marvin S. Krout shall be indicated as the Secretary of the Planning Commission.
- M. The platlor's text shall delete the language referencing the dedication to the appropriate governing body of the access easement between Lots 2 and 3.
- N. The platlor's text shall include language that a drainage plan has been developed for the plat and that all drainage easements, rights-of-way, or reserves shall remain at established grades or as modified with the approval of the applicable City or County Engineer, and unobstructed to allow for the conveyance of stormwater.

**S/D 00-17 -- Final Plat of STRUBBERS CREEK ADDITION**

**June 29, 2000 - Page 3**

- O. The applicant shall install or guarantee the installation of all utilities and facilities which are applicable and described in Article 8 of the MAPC Subdivision Regulations. (Water service and fire hydrants required by Article 8 for fire protection shall be as per the direction and approval of the Chief of the Fire Department.)
- P. The applicant's engineer is advised that the Register of Deeds is requiring the name(s) of the notary public, who acknowledges the signatures on this plat, to be printed beneath the notary's signature.
- Q. To receive mail delivery without delay, and to avoid unnecessary expense, the applicant is advised of the necessity to meet with the U.S. Postal Service Growth Management Coordinator (phone 316-729-0102) prior to development of the plat so that the type of delivery, and the tentative mailbox locations can be determined.
- R. The applicant is advised that various State and Federal requirements [specifically but not limited to the Army Corps of Engineers, Kanopolis Project Office, Rt. 1, Box 317, Valley Center, KS 67147] for the control of soil and wind erosion and the protection of wetlands may impact how this site can be developed. It is the applicant's responsibility to contact all appropriate agencies to determine any such requirements.
- S. The owner of the subdivision should be aware of the fact that the development of any subdivision greater than five (5) acres in size may require an NPDES Storm Water Discharge Permit from the Kansas Department of Health and Environment in Topeka. Further, on all construction sites, the City of Wichita requires that best management practices be used to reduce pollutant loadings in storm water runoffs.
- T. Perimeter closure computations shall be submitted with the final plat tracing.
- U. Recording of the plat within thirty (30) days after approval by the City Council and/or County Commission.
- V. The representatives from the utility companies should be prepared to comment on the need for any additional utility easements to be platted on this property.
- W. The applicant is reminded that a disk shall be submitted with the final plat tracing to the Planning Department detailing this plat in digital format in AutoCAD. This will be used by the City and County GIS Department.