

STORM WATER SEWER NO. 126 IN THE MOORINGS ADDITION

PROJECT NO.
468-76-245-80449-000-000-001

CITY OF WICHITA, KANSAS
DEAN SELLERS
ACTING CITY ENGINEER

GENERAL NOTES:

- CONTRACTOR SHALL COORDINATE WORK WITH PAVING AND SANITARY CONTRACTORS AND CONTACT RELEVANT UTILITY COMPANIES AND OTHER AGENCIES INVOLVED WITH THIS PROJECT SITE DEVELOPMENT.
- FIELD ENGINEER SHALL TAKE TIES TO ALL IRONS AND THIMBLES IN THE PROJECT AREA BEFORE CONSTRUCTION BEGINS. FIELD ENGINEER SHALL REPLACE ALL SUCH IRONS AND THIMBLES DISTURBED DURING CONSTRUCTION.
- THE TOPS OF INLETS AND MANHOLES AS NOTED ON THE PLANS MAY VARY SO AS TO MEET PROPOSED TOP OF CURB ELEVATIONS OR PAVEMENT ELEVATIONS. THE FIELD ENGINEER SHALL LOCATE INLETS AND MANHOLES WITH REFERENCE TO PROPOSED PAVING PLANS OF THE PERTINENT STREETS.
- CONTRACTOR SHALL HAVE THE OPTION OF INSTALLING PRE-CAST TYPE 1-A CURB INLET IN LIEU OF THE BRICK TYPE STRUCTURE. SEE STANDARD DETAIL PRE-CAST TYPE 1-A CURB INLET DATED AUGUST, 1979.
- ALL CONCRETE SHALL BE "6-SACK" CONCRETE UNLESS OTHERWISE NOTED.
- THE RIPRAP FOR THIS PROJECT SHALL BE TYPE 3. THE TYPE 3 RIPRAP SHALL BE 12" RIPRAP ON 6" SAND AND GRAVEL BEDDING. THE ROCK FOR RIPRAP AND GRAVEL PROTECTION SHALL BE HARD, DENSE, DURABLE AND SHALL BE REASONABLY WELL GRADED. THE SIZE RANGE OF ROCK USED SHALL BE A MAXIMUM OF ONE CUBIC FOOT AND A MINIMUM OF 1 1/2 INCH. THE 6 INCH SAND AND GRAVEL BEDDING FOR RIPRAP SHALL BE A CONTINUOUS LAYER OF SAND AND GRAVEL OR SAND AND CRUSHED ROCK, REASONABLY WELL GRADED TO A MAXIMUM OF 1 1/2 INCHES IN SIZE.
- CONTRACTOR SHALL AVOID UNCOVERING EXISTING WATER LINES UNLESS ABSOLUTELY NECESSARY. UNCOVERING SHALL BE DONE ONLY IN THE PRESENCE OF A WATER DEPT. ENGINEER.





TABLE OF CONTENTS

Sheet 1	TITLE SHEET
Sheet 2	LINES 1 to 5
Sheet 3	CONCRETE HEADWALL
Sheet 4	TYPE 1-A CURB INLET



REISS & GOODNESS ENGINEERS
2160 WEST 21st STREET
WICHITA, KANSAS 67204
(316) 622-0283



PROJ. NO. 468-76-245-80449-000 000-001


NORTH

145

140

135


130




CONCRETE HEADWALL DETAIL

The Moorings

PROJECT NO. 466-76-245-80449-090-000-001




Flap Gate Detail
Scale: 1/2" = 1'-0"



PLAN
Scale: 1/2" = 1'-0"

All exposed edges to have 1/2" Bevel



Section A-A
Scale: 1/2" = 1'-0"

HEADWALL DETAIL for 48" PIPE

a-bar	
a1	7'-3"
a2	7'-2"
a3	7'-1"
a4	7'-0"
a5	6'-11"
a6	6'-10"
a7	6'-9"
a8	6'-8"
a9	6'-7"
a10	6'-6"
a11	6'-5"
a12	6'-4"
a13	6'-3"




Table of Quantities				
Bars	Number	Length	Shape	Weight
a1	1	10'-11"		7.31
a2	1	11'-6"		7.71
a3	1	11'-11"		7.98
a4	1	12'-6"		8.38
a5	1	12'-11"		8.63
a6	1	13'-6"		9.05
a7	1	14'-1"		9.44
a8	1	14'-6"		9.72
a9	1	15'-1"		10.11
a10	1	15'-6"		10.39
a11	1	16'-1"		10.78
a12	1	16'-6"		11.06
a13	1	18'-7"		12.45
b	9	12'-9"		76.88
c	2	7'-6"		10.05
d	2	11'-1"		14.85
e	1	6'-8"		4.47
f	2	11'-0"		4.74
Total Reinforcement				244.02 lbs.
Concrete				444 C.Y.

All Rebar is #4