

GENERAL NOTES

ST. FRANCIS

- All Manholes to be City of Wichita Standards Type H and 5 ft in diameter.
- Sewer pipe to be installed by the City of Public Works, Inspection.
- All materials and construction of Manholes and Sewers shall be in accordance with City of Wichita Specifications for these items.
- Send backfill and flush all sewer excavations.
- Existing 8" Sanitary Sewer to be abandoned shall be filled with sand between the two existing manholes by the contractor. The contractor shall plug both ends of abandoned sewer with 12" of concrete.
- Existing 16" Sanitary Sewer to be abandoned shall be closed at both ends by the contractor with 36" of concrete. It is to be abandoned and removed by others.
- Match inverts of C.I.P. and V.C.P. are supported in place. The contractor shall place and compact in place with sand and asphalt and sandstone application is understood with the contractor's recommendation. After water test, the completed manhole concrete shall be completed.
- The 21" V.C.P. from M.H. #3 south to the 20" Poly-lined C.I.P. will be laid in the cut and to the south and from M.H. #4 north to the 20" P.C.P. will be laid with the bell end to the north.
- The invert of all manholes to be hand finished smooth by the contractor, a minimum of 2'4" from the 12" to the bench.
- To convert to city datum - Add 13.35' to all elevations shown.
- All manhole lids and ring to be Std. City of Wichita. Use #500AS wide flange ring.

B.M. #1 - Chis. 5' in west curb St. Francis
7'2" No. of Sp. end of East Wing
of Hospital. Elev. = 102.00

