



Note: Ditch cuts across city property and private drives to have sand backfill the full width & depth.

New Addition Under Construction

Note: Contractor to excavate to flow of 24" sewer drain & field engineer to verify elevation. The manhole elev. is approximate.

Sta 0100 Beg 12" R.C.P. Storm Sewer. Connect to exist. flow. El = 126.31

Exist. M.H. Flow = 116.95  
D = 15.72', E. Rim = 132.67  
Sta 0100 Beg 8" V.C.P. Sanitary Sewer

Sta 3145 Const. Std. M.H. Typ = "A"

Sta 1170 Const. Std. M.H. Type "A" - End 8" V.C.P. Sanitary Sewer

B.M. 132.67 East Rim Exist. Manhole.

Profile Storm Sewer

Profile Sanitary Sewer

446 L.F. 12" R.C.P. Storm Sewer

170 L.F. 8" V.C.P. Sanitary Sewer

DEC. 1967  
PRIVATE CONTRACT  
SANITARY & STORM SEWERS FOR  
ST. JOSEPH'S HOSPITAL  
CITY OF WICHITA, KANSAS  
B. E. SMITH, CITY ENGR.