

STATE	PROJECT NO.	YEAR	SHEET NO.	SHEETS
KANSAS	87N-0135-01	2005	68	137

Sta. 12+43.02, Main 1=  
B/L Sta. 22+55.71, 43.10' Lt.  
2-2" 90° Bends  
Connect to exist. 2" PVC

Sta. 12+89.06, Main 1=  
B/L Sta. 23+01.75, 14.90' Rt.  
1-8"x8" DICL MJ Tee (S)  
1-8" Anch. Valve Assy. (S)  
(MJ Gate Valve)  
Valve Box El.=188.54

② Replace Service and Meter Set  
with a 2" Service and Set.  
See Sht. 80 for details.

Sta. 26+57.12, C/L Central=  
Sta. 50+00, C/L Old Manor

① Replace Service and Meter Set with a minimum of  
1". New service to be connected to the new 8"  
Main in the South side of Central. Setter to be  
connected to existing consumer's water service.  
8-Long Services  
3-Short Services

Sta. 16+20.55 to Sta. 16+24.21, Main 1=  
B/L Sta. 26+33.24 to Sta. 26+36.90, 14.90' Rt.  
2-8" DICL MJ 45° Bends  
3.66 L.F. of 8" DICL Pipe

