

Signed J. Woods

Contractor APAC

Date

Project High Point West Add.

Project Number 472-84705

The pan-section in front of SWS inlet 1184.59 needs to be replaced. It has 3 full-length cracks.

The remainder of the job was built per plan - No other defects