










MANHOLE RING AND COVER

*See City of Wichita Standard Manhole Ring and Cover Detail Sheet for Cover Details to Be Used With Inlet Frame.



STEEL SCHEDULE

BAR	a_1	a_2	a_3	b_1	b_2	b_3	b_4	Wt. Kg.
NUMBER	4	4	2	1	3	5	7	9
SIZE	#13	#13	#13	#13	#13	#13	#13	#13
LENGTH	W=1.321 m	1.700 m	2.000 m	1.220 m	1.850 m	-	-	530 mm
	W=1.625 m	2.310 m	2.610 m	1.520 m	1.850 m	-	-	530 mm
	W=1.930 m	2.920 m	3.220 m	1.830 m	-	1.850 m	-	530 mm
	W=2.235 m	3.530 m	3.830 m	2.130 m	-	-	1.850 m	530 mm
	W=2.540 m	4.140 m	4.440 m	2.440 m	-	-	-	1.850 m

Note: a_3 Bars to be Placed Approx. 50 mm Below Top of Inlet Cover.


W	PRE-CAST TOP SIZE	PIPE SIZE	cu m Conc.
1.321 m	1.121 m 1.9 m 190 mm	525 mm & SMALLER	0.29±
1.625 m	1.425 m 1.9 m 190 mm	600 mm & 750 mm	0.39±
1.930 m	1.730 m 1.9 m 190 mm	900 mm & 1 050 mm	0.49±
2.235 m	2.035 m 1.9 m 190 mm	1 200 mm & 1 350 mm	0.59±
2.540 m	2.340 m 1.9 m 190 mm	1 500 mm & 1 650 mm	0.69±

GENERAL NOTES

- Concrete tops to be installed on thin mortar cushion to insure full support along brick walls. Concrete tops may be cast in place or precast. Concrete used for inlet construction shall be concrete pavement mix with air entrainment.
- Contractor shall have the option of constructing 200 mm brick masonry walls between the concrete inlet base and top on this inlet when W=1.90 m and H=2.1 m or less.
- Inlet invert shall be shaped with 8 sack sand mix concrete to create flow channels and to increase hydraulic efficiency such that the inlet will be self cleaning between all inlet and/or outlet pipes.
- The ends of all pipes installed in inlets shall be cut off flush with the inside face of the inlet wall.

Note:

All dimensions shown without a SI suffix are in millimeters.



STANDARD TYPE 1
CURB INLET
OPENING=150 x 1500 mm

M. E. LINDEBAK P.E. - CITY ENGINEER

PROJECT NUMBER INDEX CODE

DATE
MAR 96