

**BENCHMARK:**

BM #1 - Chiseled "X" in the Northwest Corner of the South Drive to 1305 N. Hillside.  
Elev. = 1358.70 (NAVD 88)  
BM #7 - Chiseled "C" on the Top of Curb at the Northwest Curb Return of the Driveway to 3237 E. 12th Street North.  
Elev. = 1357.22 (NAVD 88)

Prior to Beginning Construction, The Contractor Shall Excavate the Ex. 12" Water Line at Sta. 0+00.38 to Verify Size and Location. All Necessary Adjustments to the Proposed and Existing Water Lines to Make the Connections, Including Additional Water Line and Fittings, Shall be Considered **SUBSIDIARY** to the Water Line Installations.

Sta. 3+63.11, Water Line 1 =  
Sta. 0+02.00, Water Line 2 =  
B.L. Sta. 4+40.09, 22.47' Lt.  
Install 1-8" X 8" CIMJ Tee (N)  
Install 1-8" Anchored Valve Assy. (N)  
Valve Box Elev. = 1358.4

