

1 inch = 30 feet

4443

4444

8" FITTINGS  
AS NEEDED

4441

4450

CAUTION 8" VCP SANITARY SEWER.  
MAINTAIN A MINIMUM OF 24" OF CLEARANCE  
CONTRACTOR TO FIELD VERIFY DEPTH

4455

4456

4463

4462


275 LF OF 8" PIPE  
LINE 2

4469

4468

S HEMLOCK AVE

S CLIFTON AVE



	EXISTING WATER MAINS
	PROPOSED FIRE HYDRANT
	PROPOSED WATER MAIN
	PROPOSED BLOW OFF VALVE
	PROPOSED VALVE
	EXISTING FIRE HYDRANT
	SS MANHOLES
	SEWER MAINS
	STORM STRUCTURES
	STORM CONDUIT
	CUT & CAP

OAKLAWN WATERLINE  
REPLACEMENT SHEET - 13 OF 31  
448-90957 OCA 638114  
LINE 2