


1 inch = 30 feet

4600 BLOCK  
HEMLOCK CT



3417

4638

4655

8" 90° BEND

S HEMLOCK AVE

2 - 11.25 BENDS MEGALUGED WITH 8" DICL PIPE  
BETWEEN THEM AT 15' & 20' E C/L HEMLOCK  
& 3' NNCL HEMLOCK

CAUTION EXISTING 8" CI WATER MAIN

4644

8" X 8" TAPPING SLEEVE & GATE  
VALVE ASSEMBLY (E) CUT & CAP EXISTING  
8" WATER MAIN TWO TO 4 FOUR FEET  
NORTH OF TAP. 8" 90° BEND 8" DICL PIPE  
AS NEEDED

CAUTION 8" VCP SANITARY SEWER.  
MAINTAIN A MINIMUM OF 24" OF CLEARANCE  
CONTRACTOR TO FIELD VERIFY DEPTH

4650

8" X 8" X8" TEE AND 8" ANCHOR  
GATE VALVE ASSEMBLY (NE)  
LINE 2

3412

ABANDONED WATER MAIN

3404

8" PVC WL

E LOCUST DR

S HEMLOCK CT

4652

300 LF of 8" PIPE - LINE 1

3417

CAUTION 8" VCP SANITARY SEWER. MAINTAIN  
A MINIMUM OF 1' OF CLEARANCE BETWEEN  
BLOW OFF AND EDGE OF MANHOLE

4654

CAUTION EXISTING 8" CI WATER MAIN

3409

3413

4658

4656

3405

	EXISTING WATER MAINS
	PROPOSED FIRE HYDRANT
	PROPOSED WATER MAIN
	PROPOSED BLOW OFF VALVE
	PROPOSED VALVE
	EXISTING FIRE HYDRANT
	SS MANHOLES
	SEWER MAINS
	STORM STRUCTURES
	STORM CONDUIT
	CUT & CAP

OAKLAWN WATERLINE  
REPLACEMENT SHEET 5 OF 31  
448-90957 OCA 638114  
LINE 1