



Transmittal Form Chain of Custody New Main/Construction Water Quality Report

Wichita Public Works & Utilities
 Production and Pumping Division, 1800 Museum Blvd.
 Wichita Municipal Water & Wastewater Laboratory E-60603
 Phone # 316-269-4770/4771
 Fax # 316-269-4772

APPROVED BY: JC
 # OF SAMPLES: 1 RECEIPT #: 122945

Project Location: 10107 W York Contractor: Wilks Underground
 Project Number: 2175 PPW Contractor phone #: 316 640 4326
 OCA Number: 185009 Contractor fax #: _____
 Sample Collector: Chad Davis Contractor email: Chad@Wilksunderground.com

Items in gray are for Lab Use only

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl ₂	Comment
6/3	10:50	Line 1	820 1913	PASS	1.39	

- **PLEASE RETURN EMPTY BOTTLES TO LABORATORY**
- **SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM**

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature: Chad Davis Date & time 6.3 10:50 AM

CUSTODY RECORD	DATE	TIME		DATE	TIME
Relinquished by:			Received by: <u>Matt Jones</u>	6/3/19	11:08
Print Name:			Print Name: <u>Matt Jones</u>		
Relinquished by:			Received by:		
Print Name:			Print Name:		

Results Submitted by: Chad Davis Date: 6-3-19 MATT 6/3/19
 (over) Matt Jones 6/4/19