

# LIGHTING FIXTURE SCHEDULE

MARK	DESCRIPTION	MANUFACTURER		MANUFACTURER		MANUFACTURER		MANUFACTURER		LIGHT SOURCE			LENS/LOUVER/FINISH	W	L	D	REF. NOTE	REMARKS	
		NAME	MODEL	NAME	MODEL	NAME	MODEL	NAME	MODEL	#	TYPE	WATTS							VOLTS
B1	BOLLARD LIGHT	EATON	ABB-B1-LED-36-D1-A-B-K-8030							1	LED	13	UNV	BLACK	0.5	1.4	0.0	5	470LM 3000K 80CRI
DP	DECORATIVE PENDANT LIGHTING	ACCENT	CHANDELIER SILAS Y75U							1	LED	800	UNV	VINTAGE LED BULB	1.4	0.0	0.6	5	6480LM 3000K
DS	DECORATIVE WALL SCONCE	BARN LIGHT	BLE-W-PINDY2H-810-600							1	LED	60	UNV	VERIFY COLOR WITH ARCHITECT	1.1	1.3	0.8	5	800LM 3000K
EA	EMERGENCY FIXTURE	DUAL LITE	EV-4-D-02WAL							2	LED	4	UNV	WHITE					MOUNT AT 9'-0" AFF. PROVIDE BATTERY BACKUP.
EB	EMERGENCY FIXTURE	DUAL LITE	EVHC-6-06L	LITHONIA	ELM6L-UVOLT-LTP					2	LED	12	UNV	WHITE					MOUNT AT 14'-0" AFF. PROVIDE BATTERY BACKUP.
EC	EMERGENCY FIXTURE	LITHONIA	AFO-DB-MVOLT-N-SD							1	LED	3	UNV	DARK BRONZE					MOUNT AT 14'-0" AFF. PROVIDE BATTERY BACKUP.
G1	GOOSENECK LIGHT	BARN LIGHT	BLE-G-0114-850-WGG-975-CLR-LED16.8-3000K							1	LED	16	UNV	VERIFY COLOR WITH ARCHITECT	1.1	1.3	0.8	5	1600LM 3000K
GL	GAZEBO LIGHT	TLI	HRT-L18.4-12VDC-100-277V-RNG-BZ-30K-PCL-120							1	LED	18	UNV	FURNISH MOUNTING HARDWARE AS REQUIRED	1.4	0.0	0.6	5	1900LM 3000K
HA	6" RECESSED DOWNLIGHT WITH LENS	PORTFOLIO	LD6B-10-D010-EU6B-1020-80-30-6LB-M-O-LI							1	LED	13	UNV	CLEAR	0.5	1.4	0.0	5	1000LM 3000K 80CRI
HAE	6" RECESSED DOWNLIGHT WITH LENS	PORTFOLIO	LD6B-10-D010-EM14-EU6B-1020-80-30-6LB-M-O-LI							1	LED	13	UNV	CLEAR	0.5	1.4	0.0	5	1000LM 3000K 80CRI. PROVIDE BATTERY BACKUP.
K1	1X4 SURFACE FLAT PANEL	LITHONIA	EPANL-1X4-3000LM-80-30-MIN10-ZT-120							1	LED	35	UNV		1.0	4.0	0.3	5	3000LM 3000K 80CRI
K1E	1X4 SURFACE FLAT PANEL	LITHONIA	EPANL-1X4-3000LM-80-30-MIN10-ZT-120-E10W-CP							1	LED	35	UNV		1.0	4.0	0.3	5	3000LM 3000K 80CRI. PROVIDE BATTERY BACKUP.
KA	2X2 FLAT PANEL	LITHONIA	EPANL-2X2-3400LM-80-30-MIN10-ZT-120							1	LED	30	UNV		2.0	2.0	0.3	5	3400LM 3000K 80CRI
LT	LIGHTING TRACK	HALO COMMERCIAL	L653-P							1	LED	0	UNV	WHITE	0.0	12.0	0.0	8	
N4	4' STRIP	WILLIAMS	75-4-L38/830-A12125-DI-M-UNV	LITHONIA	ZL1N-L48-3000LM-FST-MVOLT-30K-80CRI					1	LED	41	UNV	ACRYLIC	0.3	4.0	0.2	5	3800LM 3000K 80CRI
N4E	4' STRIP	WILLIAMS	75-4-L38/830-A12125-DI-M-UNV	LITHONIA	ZL1N-L48-3000LM-FST-MVOLT-30K-80CRI					1	LED	41	UNV	ACRYLIC	0.3	4.0	0.2	5	3800LM 3000K 80CRI. PROVIDE BATTERY BACKUP.
P2	LED AREA LIGHT - TYPE II	MCGRAW-EDISON	GLEON-AF-02-LED-E1-T2-BK							1	LED	150	UNV	ALUMINUM, BLACK	0.0	0.0	0.0	7	11,951LM 3000K 70CRI
P4	LED AREA LIGHT - TYPE IV	MCGRAW-EDISON	GLEON-AF-02-LED-E1-T4FT-BK							1	LED	150	UNV	ALUMINUM, BLACK	0.0	0.0	0.0	7	12,252LM 3000K 70CRI
RB	BRIDGE LIGHTS	TLI	GRDW16-L12.0-TE350-120-277-BZ-30K-OEL							1	LED	12	UNV	TEXTURED BRONZE	1.1	1.3	0.8	5	1800LM 3000K
RBE	BRIDGE LIGHTS	TLI	GRDW16-L12.0-TE350-120-277-BZ-30K-OEL							1	LED	12	UNV	TEXTURED BRONZE	1.1	1.3	0.8	5	1800LM 3000K. PROVIDE BATTERY BACKUP.
S1	WALL DIRECTOR - TYPE IV	MCGRAW-EDISON	ISC-AF-1200-LED-EI-T4-FT-BZ-8030							1	LED	67	UNV	BRONZE	1.1	1.3	0.8	5	6600LM 3000K
T1	TRACK LIGHT	HALO COMMERCIAL	L-8-08-08-NF-90-30-P							1	LED	12	UNV	WHITE	0.0	0.0	0.0	5	850LM 3000K 90CRI
T2	TRACK LIGHT	HALO COMMERCIAL	L-8-08-25-FL-90-30-P							1	LED	35	UNV	WHITE	0.0	0.0	0.0	5	2500LM 3000K 90CRI
TP	TRACK PENDANT LIGHT	HALO COMMERCIAL	L1-LPM9-30-AH-P							1	LED	10	UNV	WHITE	0.0	0.0	0.0	5	560LM 3000K
V1	VANITY LIGHT	BARN LIGHT	BLE-G-2WHS-G55-WHS-12-975-12-980-E26							1	LED	200	UNV	VERIFY COLOR WITH ARCHITECT				5	3000LM 3000K
XA	1 FACE/EM EXIT	DUAL LITE	SES RBNE	LITHONIA	LE-S-1-R-ELN					1	LED	5	UNV	CAST ALUMINUM	0.0	0.0	0.0	6	RED W/BATTERY
XB	1 FACE/EM EXIT	DUAL LITE	DPIL-P-50-S-R							1	LED	5	UNV	ABS,THERMOPLASTIC	0.0	0.0	0.0	6	RED W/PHOTOLUMINESCENT

## LIGHTING FIXTURE SCHEDULE NOTES

- GENERAL CONTRACTOR SHALL PROVIDE FIREPROOFING AROUND RECESSED FIXTURES INSTALLED IN FIRE RATED CEILING PER U.L. REQUIREMENTS. ELECTRICAL CONTRACTOR WILL COORDINATE.
- MANUFACTURERS LISTED IN THIS SCHEDULE OR APPROVED BY WRITTEN ADDENDUM WILL BE THE ONLY APPROVED MANUFACTURERS TO BID THE LIGHTING FIXTURES FOR THIS PROJECT. CONTRACTORS AND SUPPLIERS USING PRICING FROM MANUFACTURERS NOT LISTED ON SCHEDULE OR BY ADDENDUM DO SO AT THEIR OWN RISK.
- LIGHT FIXTURE SELECTIONS ARE BASED ON THE MANUFACTURER IN THE LEFT MOST COLUMN AS LISTED IN THE SCHEDULE. FIXTURES APPROVED AS EQUALS IN THIS SCHEDULE OR BY ADDENDUM SHALL BE EQUAL TO THE UNIT SPECIFIED IN THE LEFT MOST COLUMN, IE: SPRING LOADED LATCHES, POST PAINTED FINISH, AND PHOTOMETRICS.
- ALL LIGHT FIXTURES SHALL BE SECURED TO THE CEILING FRAMING SYSTEM BY MECHANICAL MEANS (SUCH AS BOLTS, SCREWS, OR RIVETS) OR BY CLIPS IDENTIFIED FOR USE WITH THE TYPE OF CEILING FRAMING MEMBER AND LIGHT FIXTURE.
- LIGHT FIXTURES SHALL BE PROVIDED WITH 0-10V DIMMING DRIVERS. DRIVERS SHALL BE CAPABLE OF DIMMING TO A MINIMUM OF 10% OF TOTAL LIGHT OUTPUT. LED DRIVERS SHALL HAVE A DISCONNECTING MEANS MEETING THE REQUIREMENTS OF NEC SECTION 410.130(G), EXCEPT FOR THOSE INSTALLED IN CORD-AND-PLUG CONNECTED FIXTURES. WHERE APPLICABLE, WHEN DIMMING SWITCHES ARE NOT PROVIDED AS PART OF THE DESIGN, CONTRACTOR SHALL CAP OFF 0-10V DIMMING WIRES FOR FUTURE EXTENSION BY OWNER.
- PROVIDE ARROWS AND FACES AS INDICATED ON THE DRAWINGS.
- 30FT ROUND TAPERED STEEL POLE W/HANDHOLE AND BOLT COVERS. POLE TO MEET FIXTURE EPA REQUIREMENTS FOR THIS REGION WITH 1.3 GUST FACTOR.
- FURNISH TRACK LENGTHS AS INDICATED ON PLAN. FURNISH WITH LIVE END CONNECTORS, JOINTER CONNECTORS, AND ALL ACCESSORIES REQUIRED FOR A COMPLETE WORKING INSTALLATION.

4/1/2020 8:06:49 AM  
 BIM 360://198014-003 - Watson Park Events Center New  
 Building/198014-003-MASTER ELEC-R18.rvt

**IPEC**  
 PROFESSIONAL ENGINEERING CONSULTANTS P.A.  
 303 SOUTH TOPEKA WICHITA, KS 67202  
 316-267-2891 www.pec1.com

CITY REV  $\Delta$  13 MAR 20  
 FINAL 13 FEB 20

LIGHT FIXTURE SCHEDULE

**E0.3**

SPANGENBERG PHILLIPS TICE  
**ARCHITECTURE**  
 121 N Mead Ste 201 Wichita KS 67202  
 T 316.267.4002 F 316.267.1509  
 www.sptarchitecture.com



**WATSON PARK**  
**EVENT CENTER**  
 3022 S MCLEAN BLVD, WICHITA, KS 67217