



LIGHT FIXTURE TYPE "F" IS SUPPLIED WITH WET LABEL REMOTE BALLAST. MOUNT BEHIND SIGN AS PER ARCH.
 LIGHT FIXTURE TYPE "D" IS MOUNTED ON A SHORTEN GOOSENECK BRACKET # GB-AS, SHORTENED 7".
 LIGHT FIXTURE TYPE "D" USES A WET LABEL REMOTE BALLAST. MOUNT AS PER ARCH.

CHANGE - SHEET EL4 LIGHT FIXTURE SCHEDULE - FIXTURE TYPE E
CHANGE TO 250W MH 4' X 8' NEWAL BEAM SPREAD W/ YOKE MOUNTING.
FIXTURE SHALL HAVE COMPACT DIE-CAST ALUMINUM HOUSING WITH FULL VISO.
FIXTURE SHALL BE EQUAL TO UTHONIA # 1FR250W-TFRFY-DBL. PROVIDE FLUSH MOUNTED
FS BOX WITH LIQUID-TIGHT CONDUIT TO FIXTURE. FLUSH MOUNT FS BOX AND MOUNT
FIXTURE YOKE TO A 12" X 18" X 12", FLUSH CONCRETE BASE. PROVIDE UNI-STRUT SPACER
BETWEEN FIXTURE YOKE AND CONCRETE BASE AS REQUIRED FOR CORRECT FIXTURE AIMING.
PROVIDE A SEPARATE 20A 120V CIRCUIT, USING #10AWG CONDUCTORS, FROM PANEL "SC2".

