



1 in = 40 ft  
11"x17"

The cross connection between the 2" and 24" mains is to be killed. Plug the 2" Valve attached to the Lockjoint water main and leave the Valve Box to grade

Install approx. 505 LF 8" PVC by Directional Drilling Methods

4" Gas

Ex. 2" CI Water Main

Remove Ex. Blowoff

53072

2" Cast Iron

53070

2" Cast Iron

Overhead Electric

Install FH Assembly

Overhead Electric

CAUTION!  
Ex. 24" PCSC  
Water Main



Service Lines:

630 N Estelle - Install 1" Service Line - Repl. Ex. 1" Meter  
635 N Estelle - Install 1" Service Line - Install 1" Meter  
636 N Estelle - Install 1" Service Line - Install 1" Meter  
637 N Estelle - Install 1" Service Line - Install 1" Meter  
639 N Estelle - Install 1" Service Line - Install 1" Meter  
642 N Estelle - Install 1" Service Line - Install 1" Meter  
651 N Estelle - Install 1" Service Line - Install 1" Meter

652 N Estelle - Install 1" Service Line - Install 1" Meter  
655 N Estelle - Install 1" Service Line - Repl Ex. 1" Meter  
658 N Estelle - Install 1" Service Line - Install 1" Meter  
660 N Estelle - Install 1" Service Line - Repl Ex. 1" Meter  
661 N Estelle - Install 1" Service Line - Install 1" Meter  
801 N Estelle - Install 1" Service Line - Install 1" Meter  
802 N Estelle - Install 1" Service Line - Install 1" Meter

805 N Estelle - Install 1" Service Line - Install 1" Meter  
806 N Estelle - Install 1" Service Line - Install 1" Meter  
812 N Estelle - Install 1" Service Line - Install 1" Meter

RANDOM WATER MAIN -  
ESTELLE REPLACEMENT -  
PHASE B 448-2022-005518  
MUNIS NO W0034  
ORG CODE 54250020  
SHEET 5 OF 14