

PLAN NOTES

1. E.C. SHALL COORDINATE ALL WORK WITH IRRIGATION CONTRACTOR.
2. E.C. SHALL USE EXISTING 6" SLEEVES BETWEEN ISLANDS AND CURB.
E.C. SHALL REWORK THE EXISTING 6" SLEEVES TO ALLOW 36"-48" COVER.
3. E.C. SHALL MAINTAIN A MIN. COVER OF 36" OVER ALL U.G. CONDUITS.
E.C. SHALL INCREASE CONDUIT COVER WITHIN THE STREET ISLANDS TO 48" MIN. TO CLEAR THE IRRIGATION AND TREE PLANTING EXCAVATION.
MAINTAIN 12" CLEARANCE UNDER ALL IRRIGATION PIPING.
4. E.C. SHALL PROVIDE 1ea. 15 AMP 120 VOLT UNSWITCHED CIRCUIT TO THE IRRIGATION CONTROLLER. IRRIGATION CONTROL PROVIDED AND MOUNTED BY IRRIGATION CONTRACTOR.

NOTE: INSTALL POWER RECEPTACLE LOCATIONS AS INDICATED ON LANDSCAPE PLANS, RELATIVE TO TREE LOCATIONS.


NEW METERING PEDESTAL
REF. TO METERING DETAIL

CONDUIT AND RISER
TYP.


EXISTING KGE POLE
NEW UNMETERED DIP LOC.
VERIFY EXACT LOCATION.
COORDINATE EXACT LOCATION
OF NEW METER PEDESTAL W/ ARCH.
REFER TO ALL TO ARCH DETAILS

ELECTRICAL PLAN NO. 3

1" = 30'




ELECTRICAL KEY PLAN



SHEET E4

METER CENTER #3



MKEC
ENGINEERING CONSULTANTS
411 N. WEBB ROAD
WICHITA, KS. 67206
316-684-9600

SENECA STREET
PROJECT NAME

ELECTRICAL PLAN NO. 3
SHEET TITLE

DAJ	DAJ	DAJ
DESIGN BY	DRAWN BY	CHECKED BY
2/3/03	E4	E4 / 5
DATE	DRAWING NAME	SHEET / DF