

princeps

This plot approved and a
herean accepted by the Board
Wichita, Kansas, this ____ day of

Three rods - - - - -

**CONFIRMATION
MEMO**

DATE 2-6-84

COPIES TO:

FROM N. Brent Wooten

REFERENCE Final drainage plan

The lot will be developed for a Quick Trip site with a runoff factor of 0.90 used.

Lot 1 (0.60^{ac}) will drain north to Maple and East to Tyler thru Drives. Tyler and Maple adjacent to this plat are to be paved to standards with a ^{grade} ~~cross~~ canalized intersection. Presently both are asphalt mat streets with ditches.

RECEIVED
FEB 8 1961
Dept. of Justice