

Record Drawings III

VOLUME V

VOLUME IV

VOLUME III

VOLUME II

VOLUME I

ADDENDUM #1:

- Sheet 435**
1. **Revise the total quantity for the "Surface Coating Finish" for Br. 19.05(W.B.) from 394 square meters to 741 square meters.**
 2. **Revise the total quantity for the "Surface Coating Finish" for Br. 19.06(E.B.) from 436 square meters to 731 square meters.**
 3. **Replace the "Elastomeric Bearing Devices" at the Abutments for Br. Nos. 19.05 (W.B.) and 19.06 (E.B.) with "TFE Elastomeric Bearing Devices." The bid item "TFE Elastomeric Bearing Devices" needs to be added to the plans for both bridges. The revised quantities for the bid items shall be as follows:
Abutment No. 1: "TFE Elastomeric Bearing Devices" (8 Required).
Abutment No. 2: "TFE Elastomeric Bearing Devices" (8 Required).
Total "TFE Elastomeric Bearing Devices" (16 Required).
Pier No. 1: "Elastomeric Bearing Devices" (8 Required).
Pier No. 2: "Elastomeric Bearing Devices" (8 Required).
Total "Elastomeric Bearing Devices" (16 Required).**
 4. **Revise the total quantity for the "Special Surface Treatment" for Br. 19.05(W.B.) from 152 square meters to 76 square meters (38 sq. m. per abutment).**
 5. **Revise the total quantity for the "Special Surface Treatment" for Br. 19.06(E.B.) from 152 square meters to 76 square meters (38 sq. m. per abutment).**

ADDENDUM #3:

The following paragraphs are added to clarify the notes included in the plans regarding painting of the structural steel girders. The referenced plan sheet notes are found under the heading "PAINTING" on Sheet Nos. 435 and 565:

1. **Painting of the girders shall generally be in compliance with the KDOT Specifications.**
2. **The interior portions of the box girders shall receive either two coats in the shop, which consist of an inorganic zinc prime coat (3 mil minimum DFT) and a waterborne acrylic final coat (3 mil minimum DFT); OR, an inorganic zinc prime coat (3 mil minimum DFT) applied in the shop and a waterborne acrylic final coat (3 mil minimum DFT) applied in the field.**
3. **For either case, the final coat applied to the interior portions of the box girders shall be white.**
4. **The exterior portions of the box girders shall receive an inorganic zinc prime coat applied in the shop. The exposed exterior portions of the girders shall receive a waterborne acrylic final coat applied in the field after erection. The final coat shall be an approved waterborne acrylic paint in color #20372 (Buckskin) of Federal Standard 595B.**

