

FHWA REGION NO.	STATE	PROJECT NO.	YEAR	SHEET NO.	TOTAL SHEETS
7	KANSAS	54-87 K-6657-01	2002	648	1122

- (C) DUCT: THE DUCT FOR SECONDARY CABLE UNDERGROUND SHALL BE POLYETHYLENE DUCT WITH MINIMUM TENSILE STRENGTH OF 21,500 Pa. DUCT TO PROVIDE FOR 40% MAXIMUM FILL. THE DUCT SHALL MEET A.S.T.M D3485 (LATEST REVISION).
- (D) LUMINAIRES: ALL LUMINAIRES SHALL BE SUPPLIED WITH HIGH POWER FACTOR BALLAST. COLOR OF LUMINAIRES SHALL BE BLACK.
 - (a) 250 WATT LUMINAIRES: 250 WATT LUMINAIRES SHALL HAVE A HOUSING OF ALUMINUM ALLOY CASTING WITH AN INTEGRAL SLIPFITTER FOR A 50 mm BRACKET MOUNTING WITH A NATURAL UNPAINTED ALZAK ALUMINUM REFLECTOR. THE BALLASTS SHALL BE A VOLTAGE AUTO-REGULATOR TYPE FOR HIGH PRESSURE SODIUM AT A VOLTAGE OF 480 VOLTS. THE REFRACTORS SHALL BE ACRYLIC WITH TYPE III LIGHT DISTRIBUTION.
- (E) SODIUM LUMINAIRE IGNITORS: ALL HPS LUMINAIRES SHALL BE EQUIPPED WITH THE FOLLOWING:
 - (a) HIGH PRESSURE SODIUM IGNITORS: ELECTRONIC IGNITOR FOR THE IGNITION OF HIGH PRESSURE SODIUM (HPS) VAPOR LAMPS. THE IGNITOR SHALL BE DESIGNED TO DIRECT THE HIGH VOLTAGE SPIKE DIRECTLY TO THE LAMP WITHOUT BEING DIRECTED TO THE LAMP THROUGH THE BALLAST WINDINGS. THE IGNITOR SHALL BE CAPABLE OF BEING USED WITH ALL BRANDS AND TYPES OF 60 HERTZ HPS BRANDS. THE IGNITOR SHALL BE DESIGNED SO THAT CYCLING OR EXTINGUISHED LAMP SHALL NOT ADVERSELY AFFECT THE IGNITOR OR BALLAST. THE IGNITOR SHALL BE BE TOTALLY EPOXY ENCAPSULATED IN A METAL CAN AND SHALL BE OPEN CIRCUIT TESTED FOR A PERIOD OF 48 HOURS WITH POWER APPLIED AT ELEVATED TEMPERATURES TO 100~C WITH CONSTANT MONITORING OF CASE TEMPERATURES. THE IGNITOR SHALL HAVE A TWO (2) MINUTE TIME DELAY. IF THE LAMP DOES NOT START, THE IGNITOR WILL BE SHUT OFF UNTIL THE POWER TO THE LUMINAIRES IS RESET BY THE PHOTO CONTROL. THE IGNITOR SHALL BE WARRANTED AGAINST DEFECTIVE MATERIALS AND WORKMANSHIP FOR A PERIOD OF NOT LESS THAN FIVE (5) YEARS FROM THE SHIPPING DATE.
- (F) LAMPS
 - (a) 250 WATT LAMPS: 250 WATT LAMPS SHALL BE 28,000 LUMEN, CLEAR HIGH PRESSURE SODIUM, 24,000 HOUR LAMP.
- (G) ENCLOSURE: THE ENCLOSURE CABINET SHALL BE CONSTRUCTED OF 5052 ALLOY ALUMINUM 3 mm THICK. THE CABINET SHALL BE OF CLEAN CUT DESIGN HAVING NO SHARP EDGES, CORNERS OR PROJECTIONS. THE CIRCUITING SHALL BE SERVICEABLE BY MEANS OF A FULL LENGTH HINGED DOOR WITH PADLOCK PROVISIONS. THE ENCLOSURE SHALL HAVE 600 VOLT RATED MOLDED CASE MAIN AND SECONDARY BREAKERS, TWIST-LOCK PHOTO-CELL SOCKET, AND MERCURY CONTACTORS. THE EQUIPMENT WITHIN THE ENCLOSURE SHALL BE WIRED PRIOR TO DELIVERY. THE ENCLOSURE SHALL HAVE A METER VIEW WINDOW AND A GLASS TO ALLOW LIGHT TO THE PHOTO-CELL.

- (a) MAIN AND SECONDARY BREAKERS: THE MAIN AND SECONDARY BREAKERS SHALL HAVE A MOUNTING DIMENSIONS OF 35 mm WIDE BY 115 mm HIGH MOUNTING HOLES SHALL BE POSITIONED TO ACCOMODATE A BREAKER 70 mm WIDE SIDE BY SIDE. SEE ENCLOSURE DETAIL SHEET.

GENERAL MATERIALS AND NOTES:

- (A) MISCELLANEOUS HARDWARE: MISCELLANEOUS HARDWARE THAT REQUIRES GALVANIZING OR ELECTROPLATING SHALL CONFORM TO THE STANDARD SPECIFICATIONS, 1990 EDITION, SECTION 1703 (c).
- (B) METALLIC CONDUIT: METALLIC CONDUIT SHALL BE RIGID STEEL CONDUIT MEETING THE REQUIREMENTS OF AMERICAN STANDARD SPECIFICATION C-80.1. TRENCHING FOR CONDUIT WILL NOT BE PERMITTED THROUGH EXISTING PAVEMENT. JACKING WILL NOT BE PERMITTED IN DISTRICT ONE UNLESS APPROVED BY THE ENGINEER IN CHARGE OF CONSTRUCTION.
- (C) METALLIC CONDUIT FITTINGS: METALLIC CONDUIT FITTINGS SHALL BE ZINC COATED AND SHALL MEET THE REQUIREMENTS OF AMERICAN STANDARD SPECIFICATION C-80.1.
- (D) NON-METALIC CONDUIT: NON-METALIC CONDUIT SHALL BE RIGID POLYVINYL CHLORIDE MEETING THE REQUIREMENTS OF FEDERAL SPECIFICATIONS NO. L.P. 1036A, TYPE II, ELECTRICAL CLASS 2, GRADE C. EACH LENGTH SHALL BEAR THE UNDERWRITERS, INC. LABEL.
- (E) NON-METALIC CONDUIT FITTINGS: NON-METALLIC CONDUIT FITTINGS SHALL BE FABRICATED FROM POLYVINYL CHLORIDE HAVING THE SAME CHEMICAL AND PHYSICAL PROPERTIES AS THE CONDUIT WITH WHICH IT IS TO BE USED. EACH SHALL BEAR THE UNDERWRITERS, INC. LABEL. THE JOINTS SHALL BE MADE IN ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS.
- (F) GROUND: GROUND WIRE SHALL BE A #6 AWG SOLID BARE COPPER WIRE AND ARRANGEMENT SHALL BE AS NOTED ON PLANS.
- (G) ANCHOR BOLTS: ANCHOR BOLTS SHALL CONFORM TO THE STANDARD SPECIFICATIONS, 1990 EDITION, SECTION 1613, TYPE I FOR LIGHT STANDARDS.
- (H) JUNCTION BOX: JUNCTION BOX SHALL BE MADE OF 2 mm SHEET METAL (STEEL) WITH WELDED SEAMS, KNOCKOUTS AND WEATHERPROOF SCREW COVER. BOXES SHALL BE HOT DIPPED GALVANIZED IN ACCORDANCE WITH A.S.T.M. A-123 OR ELECTROPLATED WITH A MINIMUM THICKNESS OF 1 mm AFTER FABRICATION. THE SURFACE OF THE JUNCTION BOX WHICH COMES IN CONTACT WITH CONCRETE SHALL BE COVERED WITH ALUMINUM COLORED BUTYL RUBBER SEALANT (CAULKING COMPOUND).
- (I) WEDGE TYPE STUD BOLT ANCHORS: THE CONTRACTOR SHALL INSTALL TWO 10 mm X 75 mm WEDGE TYPE ANCHORS FOR CONDUIT CLAMPS. THE ANCHORS SHALL BE WEDGE TYPE MADE FROM CARBON STEEL MEETING AISI 12L14 STEEL. THE MINIMUM EMBEDDED DEPTH SHALL BE 45 mm.
- (J) CONDUIT CLAMPS WITH CLAMP BACKS: THE CONTRACTOR SHALL INSTALL 50 mm CONDUIT CLAMPS WITH A COMPATIBLE CLAMP BACK. CLAMPS SHALL BE HEAVY DUTY STEEL TO SECURE THE 50 mm RIGID CONDUIT TO STRUCTURE. CONDUIT CLAMPS ARE TO BE SPACED AT 1.8 m INTERVALS.
- (K) ALL WELDS SHALL BE SMOOTH CLEAN DENSE DEPOSIT THAT WILL EXCLUDE MOISTURE AND CONFORM TO A.W.S. SPECIFICATION D1.1 (LATEST REVISION). FIELD WELDS WILL NOT BE ALLOWED.
- (L) CABLE CONNECTORS: CABLE CONNECTORS FOR THE CONNECTIONS IN LIGHT STANDARD BASE SHALL BE THE FUSED CONNECTOR KIT TYPE WITH A MOLDED RUBBER HOUSING FOR WATERPROOFING. CONNECTORS SIZED TO FIT CABLE.

- (M) FRANGIBLE BASE: FRANGIBLE BASE SHALL BE CAST ALUMINUM TO MEET MEET THE STANDARDS OF THE 1985 A.A.S.H.T.O. STANDARD SPECIFICATIONS FOR STRUCTURAL SUPPORTS FOR HIGHWAY SIGNS, AND TRAFFIC SIGNALS. THE FRANGIBLE BASE SHALL ACCOMODATE A 320 mm BOLT CIRCLE TOP AND BOTTOM. THE FRANGIBLE BASE SHALL HAVE HIGH DENSITY PLASTIC DOORS. THE COLOR SHALL BE PIGMENTED THROUGHOUT TO GIVE THE APPEARANCE OF ALUMINUM. THE DOORS SHALL WITHSTAND TEMPERATURE EXTREMES OF -57 DEGREES TO 66 DEGREES C. AND ARE COMPOUNDED WITH U.V. INHIBITORS.
- (N) CABLE GRIP SUPPORTS: THE CONTRACTOR SHALL INSTALL ONE (1) CABLE SUPPORT GRIP IN EACH ROADWAY LIGHTING POLE. THE CABLE SUPPORT GRIP SHALL BE MADE OF HIGH GRADE, NON-MAGNETIC TIN COATED BRONZE STRAND. THE CABLE SUPPORT GRIP SHALL BE CAPABLE OF SECURING TWO (2) #10 AWG TYPE USE-2 CABLES IN A VERTICAL POSITION HOLDING THE WEIGHT OF THE CABLES AND CABLE CONNECTORS OFF THE LUMINAIRE ASSEMBLY. SEE ROADWAY LIGHTING DETAILS SHEET.
- (O) GROUND RODS: RODS SHALL BE COPPERCLAD STEEL, 20mm DIAMETER BY 3m LONG.

DSNR: WAN OPER: WAN SCALE: 500
 E:1997/97362/WK4648.DGN 4-10-2002 7:37:13 LAST REV: BY:

3				
2				
1				
NO.	DATE	REVISION	BY	APP'D
KANSAS DEPARTMENT OF TRANSPORTATION				
CONSTRUCTION AND MATERIAL REQUIREMENTS FOR HIGHWAY LIGHTING				
FE20751				
FHWA APPROVAL	8/16/94	APP'D	LINDA G. VOSS	
DESIGNED	KG	DETAILED	MALENSCOMB	QUANTITIES
DESIGN CK.		DETAIL CK.	LV	QUAN. CK.
				TRACE CK.