

**MANHOLE CLOSURE DETAIL**  
NO SCALE

NOTES:  
ALL EXCAVATION SHALL BE BACKFILLED WITH FLOWABLE FILL.


A REPRESENTATIVE OF THE CITY OF WICHITA WATER AND SEWER DEPARTMENT SHALL BE PRESENT DURING MANHOLE CLOSURE. CONTACT MR. BILL PERKINS AT (316) 268-4555 FOR COORDINATION.

CONTRACTOR IS REQUIRED TO MAINTAIN CONTINUOUS FLOW OF SEWAGE IN EXISTING MAIN AT ALL TIMES.

CLOSURE SEQUENCE:  
Recommended Closure Sequence is provided below. If contractor varies from this sequence, it shall be submitted to the Engineer for approval prior to beginning construction. All items listed in the sequence shall be accomplished per the detail.

- 1.) Remove and dispose of barrel and cone sections.
- 2.) Inspect physical condition of concrete structure.
- 3.) Provide coating on top of existing structure (entire structure if existing is epoxy coated).
- 4.) Provide minimum overlap of plastic liner (only if plastic liner exists).
- 5.) Coat Pre-cast slab after it has been inspected and accepted.
- 6.) Install slab on existing concrete structure, as shown in the Manhole Closure Detail.
- 7.) Provide flowable fill from the top of Precast Concrete slab to the existing ground elevation.

**RECORD DRAWING**

1			
No.	Revisions	By	Date
CITY OF WICHITA, KANSAS			
MANHOLE CLOSURE DETAIL			
SEDGWICK COUNTY			
 <b>Professional Engineering Consultants, P.A.</b> 303 S. TOPEKA • WICHITA, KANSAS 67202 316-262-2691 • FAX 316-262-3003			
Designed by	KJW	Checked by	MDK
Drawn by	TDS	Date	APRIL, 2002
		Job No.	97362