

BENCHMARK:
 BM #4 - Small RR spike Located in South Face of Pwr-Pole at the NE Corner of the Intersection of Mosley and 3rd Street North.
 Elev. = 1297.92 (MSL)

W.L. Sta. 4+29.88, Line 1 =
 B.L. 2 Sta. 13+98.56, 17.50' Rt.
 Install 1-24" X 6" CIMJ Tee (S)
 Install 1-6" X 4" CIMJ Reducer (S)
 Install 1-4" Anch Valve Assy. (S) (Gate Valve)
 Install 13.50 L.F. 4" Pipe (S)
 Install 1-4" CIMJ 90° Bend (Rt.)
 Install 3.00 L.F. 4" DI CL Pipe (W)
 Install 1-4" CIMJ 90° Bend (Lt.)
 Reconnect Exist. Service Valve Box Elev. = 1297.17 Top
 Install 1-4" MJ Cap (N)

W.L. Sta. 3+81.32, Line 1 =
 B.L. 2 Sta. 13+50.00 =
 Match Point.

W.L. Sta. 4+19.08, Line 1 =
 B.L. Sta. 13+87.76, 17.50' Rt.
 Install 1-2" Service Outlet Assy
 Install 16.50 L.F. 2" Pipe (S)
 Reconnect Exist. Service Valve Box Elev. = 1297.22

W.L. Sta. 4+83.07, Line 1 =
 W.L. Sta. 0+00.00, Line 1a =
 B.L. 2 Sta. 14+51.75, 17.50' Rt.
 Install 1-24" X 8" CIMJ Tee (N)
 Install 1-8" Anch Valve Assy. (N) (Gate Valve)
 Valve Box Elev. = 1296.96 Top

W.L. Sta. 6+77.44, Line 1 =
 B.L. 2 Sta. 16+46.07, 17.50' Rt.
 Install 1-24" X 12" CIMJ Tee (S)
 Install 1-12" Anch Valve Assy. (S) (Butterfly Valve)
 Install 9.00 L.F. 12" DI CL Pipe
 Install 1-12" CIMJ 90° Bend (W) Rolled
 Install 6.00 L.F. 12" DI CL Pipe (W)
 Install 1-12" 90° CIMJ Bend (S)
 Connect to Ex. 12" Water Line Valve Box Elev. = 1297.87
 Install 1-12" MJ Cap (N)

Note:
 See Water Meter Table For Service Locations.

