

\*\* The Water Meter, Meter Setter, Meter Box, Ring and Lid shall be re-used and reset unless damaged or determined unsuitable for use by the Construction Engineer or his representative. The Contractor will provide the new service materials as needed. All new service materials shall be in accordance with City of Wichita, Kansas Standard Specifications.


**RELOCATE EXISTING WATER METER DETAIL**

RELOCATE EXISTING WATER METER TABLE			
@ TOPKEA ST. STATION	PROPOSED TAP LOCATION	PROPOSED METER LOCATION	APPROXIMATE 1" SERVICE LINE REQUIRED (FT.)
491+45	30' Rt.	37' Lt.	7'
491+47	31' Rt.	37' Lt.	6'

TOTAL METER BOXES = 2  
 APPROXIMATE 1" SERVICE LINE = 13'

Note:  
 Services will be bid on a per each basis.  
 No adjustment in cost will be made for modifications to the approximate length as shown. Minimum depth of bury 42".

Contractor shall verify existing service line Size prior to installing services.



No.	Revision	By	Date
<b>WATERLINE MODIFICATIONS</b> <b>TOPEKA AND LEWIS STREET INTERSECTION</b> <b>MISCELLANEOUS DETAILS</b> JAMES L. ARMOUR, P.E. - CITY ENGINEER CITY OF WICHITA PROJECT NO. 448-90424 <b>Professional Engineering Consultants, P.A.</b> 303 S. TOPEKA • WICHITA, KANSAS 67202 316-262-2691 • FAX 316-262-3003			
Designed by	MDK	Job No.	35-08456-001
Drawn by	CSL, RJW	Date	November 2008
			Sht. W5 of 8