



- MATERIALS LIST**
- 1-MU GATE OR BUTTERFLY VALVE (AS PER PLAN)
 - 1-6" VALVE BOX
 - 2-COUPPLINGS
 - 2-SHORT PCS. (DIAG. SU PIPE)
 - CONCRETE SUPPORT BLOCK SHALL BE FULL WIDTH OF THE TRENCH

LINE VALVE ASSEMBLY




- MATERIALS LIST**
- 1-MU GATE OR BUTTERFLY VALVE (AS PER PLAN)
 - 1-6" VALVE BOX
 - CONCRETE SUPPORT BLOCK SHALL BE FULL WIDTH OF THE TRENCH
 - 1-MU ANCHOR COUPLING (12" OR SMALLER)

ANCHORED VALVE ASSEMBLY



- MATERIALS LIST**
- 1-MU GATE OR BUTTERFLY VALVE (AS PER PLAN)
 - 1-6" VALVE BOX
 - 2- 2" DIAM. SU PIPE
 - CONCRETE SUPPORT BLOCK SHALL BE FULL WIDTH OF THE TRENCH


VALVE ASSEMBLY



NOTES

- This detail covers Butterfly Valve installation, inclusive, regard-less of type of pipe or joint used. Large lines to be detailed on plans.
- Valve Box and Cover required per City of Wichita Std. Specifications.
- Conc. Support Block to be full width of trench.

CONCRETE SUPPORT BLOCKING FOR BUTTERFLY VALVE INSTALLATION



- MATERIALS LIST**
- 1-MU ANCHOR TEE (12" x 6")
 - 1-6" MU GATE VALVE
 - 1-6" VALVE BOX
 - 6" DIAM. SU PIPE (20" MAX)
 - 1-FIRE HYDRANT CONCRETE BLOCKING (AS NEEDED)


** CAUTION! WEEP HOLES TO BE KEPT CLEAR DURING CONSTRUCTION AND BACKFILL. CONCRETE FOR THRUST BLOCKING SHALL NOT OBSTRUCT WEEP HOLES.

CONCRETE THRUST BLOCKING SHALL BE KEPT CLEAR OF BOLTS, NUTS, AND MU ACCESSORIES.


* IF HYDRANT BURY IS IN EXCESS OF 5', CONTRACTOR SHALL USE STANDARD 5" HYDRANT BURY AND HYDRANT BARREL EXTENSIONS AS NECESSARY.

FIRE HYDRANTS REQUIRED			
STATION	BURY LINE ELEVATION	TOP OF PIPE BURY ELEVATION	FIRE HYDRANT BURY REQUIRED*
0+95 LINE 1	1272.00	1274.13	4.5'


FIRE HYDRANT ASSEMBLY PER CITY OF WICHITA SPECIFICATIONS



KEY BLOCK DETAIL




ANCHORED VALVE ASSEMBLY, SPECIAL




- Notes:**
- Concrete Block at Valve to have sufficient bearing in undisturbed soil to prevent thrust movement as shown in table at right. Field Engineer to determine thrust loading of undisturbed soil and final size of thrust block.
 - The thrust block shall be constructed such that bolts, nuts, and other MU accessories are kept clear of concrete, called out on the plans shall be blocked as shown here.

THRUST AT VALVES	THRUST AT 150 F/W
4"	1809 lbs.
6"	4245 lbs.
8"	7540 lbs.
12"	16985 lbs.

PROTECTIVE FILL DETAIL



2\"/>



- MATERIALS LIST**
- 1-2" VALVE BOX
 - 1-CMU CAP
 - 1-2"x6" BRASS NIPPLE
 - 1-2" IPT MUELLER VALVE A-2395-8-OI
 - 2- HEAD OR APPROVED EQUAL
 - 1-GALV. STREET EL.
 - 2- GALV. PIPE (AS REQUIRED)
 - 1-2" GALV. PULL-AND-TIGHTENED
 - 1-2" GALV. PLOG (HAND TIGHTENED)

TRACER WIRE

Conductive type pipe locator/tracer wire shall be installed to locate Polyvinyl Chloride (PVC) or any nonmetallic waterline pipes. The wire shall extend the entire length of the proposed pipe. The wire shall be taped to the waterline and pulled with the pipe. Split-bolt connectors shall be used at splice locations. Electrical tape shall cover all splices so no bare wire is exposed. Test stations shall be installed adjacent to all the hydrants along the waterline and at blowoffs or valves near the ends of the waterlines. Any exceptions to the location of test stations shall be approved by the engineer. At each test station, the tracer wire shall be connected to a 1 lb. zinc or magnesium anode. Anodes shall also be attached to the tracer wire at both the beginning and the end of the proposed waterline. A typical layout of the tracer wire and test station is provided in the above figure.

WIRE

The tracer wire shall be Blue No. 12 THHN annealed soft copper wire with thermal plastic insulation. The insulation shall be heat, oil, and gasoline resistant as manufactured by Temple Electric or approved equal. To allow for grade adjustment, a minimum of 12" of excess wire shall be coiled at the bottom of the test station for all wires. The insulation sheathing shall be removed such that 1" bare copper wire is exposed at all points of connection. Contractor shall attach wire being installed with proposed water main to any tracer wire installed with adjacent waterline projects.

TEST STATIONS

The test station for fire hydrant applications shall be a 1 inch galvanized conduit style test station as manufactured by AGFA Industries with a removable solid cover having two leads extending from the face or approved equal. The test station for valve applications shall be a 2 inch flush style test station 12FS29 as manufactured by HANDLEY Industries or approved equal. The conduit style shall be attached to a 1 inch rigid galvanized conduit with a minimum length of 36" and plastic end bushing. The flush style shall have the word "WATER" stamped or molded into the lid. All test stations shall be manufactured using molded blue tops or sufficiently coated with blue enamel paint. The tracer wire and the anode wire shall be installed to allow 10 inches of wire within the test station. In concrete environments such as sidewalks or in the downtown area the contractor shall use the flush style test station. The location of all test stations shall be approved by the engineer, recorded, and shown in the as-built drawings.

ANODES

The anodes shall be 1 lb. bare zinc or magnesium. The anodes shall be buried at the same elevation as the waterline of each test station. The anodes shall be connected to Black No. 12 THHN annealed soft copper wire which shall be extended to the test station.

TRACER WIRE DETAIL

COST IS SUBSIDIARY TO PIPE INSTALLATION

Revised: 6-7-00, MCC

	STANDARD WATER ASSEMBLY DETAILS	
	JAMES L. ANJOUR, P.E. - CITY ENGINEER	DATE
PROJECT NUMBER	448-90420	DESIGN NUMBER
DATE	DEC 98	SHEET
2 OF 9		