


CUT AND REMOVE A SUFFICIENT LENGTH OF 8" PVC PIPE IN ORDER TO INSTALL 1-2" BLOWOFF ASSY. CAP AND ABANDON PIPE TO THE NORTH.

29

REMOVE AND REINSTALL EXISTING FIRE HYDRANT AFTER INSTALLING AN ADDITIONAL 12.0 L.F. OF 6" DI CL PIPE. (HYDT. TO SET 3' BACK OF NEW CURB.)

31

 <p>MKEC ENGINEERING CONSULTANTS 411 N. WEBB ROAD WICHITA, KS. 67206 316 - 684 - 9600</p>	WILSON FARMS SECOND ADD. PHASE 1A PROJECT NAME		
	WATER PLAN SHEET TITLE		
	GJA/JTC DESIGN BY:	DM DRAWN BY:	GJA/JTC CHECKED BY:
	OCTOBER 2001 DATE	01202C1 JOB NO.	13 / 16 SHEET/OF