

ENGINEERING DEPARTMENT

CITY OF WICHITA

MISCELLANEOUS INFORMATION

Signed

Spencer Cody

Contractor

Cornejo + Sons.

Date

12-02-09

Project

Zoo park Circle - Cox Machine 3rd Addition

Project Number

472-84820

The base lift of asphalt was defective from station St 20.0 to station ^{6+50.0} on the West half of the roadway. The defective asphalt was removed and replaced. The remaining portion of the project was completed as specified per plan.