


SCALE:
HORIZONTAL: 1" = 20'
VERTICAL: 1" = 5'



Sta. 11+59.22, Water Line 16 =
B.L. Sta. 13+15.10, 19.0' Lt.
Deflect Pipe 3'19'42" (Rt.)
Install 1-8" X 8" CIMJ Tee (SW)
Install 2-8" Anchored Valve Assy. (NW & SE)
Valve Box Elev. = 1339.7
Install 5.00 L.F. 8" DI CL Pipe (SW)
Install 1-8" 90° CIMJ Bend (SE)
Install 5.04 L.F. 8" DI CL Pipe (SE)
Tap Ex. 10" Water Line.
Install 1-10" X 8" Tapping Sleeve (NW) & 8"
Tapping Valve with Valve Box to be Furnished
& Installed by the City of Wichita.
Valve Box Elev. = 1339.3

Sta. 10+00.00, Water Line 16 =
B.L. Sta. 11+56.06, 18.0' Lt.
(Match Point)

Sta. 11+39.22, Water Line 16 =
B.L. Sta. 12+95.27, 18.0' Lt.
Deflect Pipe 2'50'18" (Lt.)

Sta. 12+18.19, Water Line 16 =
B.L. Sta. 13+74.24, 19.0' Lt.
Deflect Pipe 0'33'57" (Rt.)

Install 440.78 L.F.
8" Pipe.

Sta. 16+00.00, Water Line 16 =
B.L. Sta. 17+56.05, 19.1' Lt.
(Match Point)

CAUTION!
Existing
Water
Crossing

CAUTION!
Existing
San. Sewer
Crossing



Location of Existing Line is Based on Record Information from the City. The Contractor Shall Excavate the Ex. Water and to Verify Size and Location PRIOR to Beginning Construction. This Work Shall be Considered SUBSIDIARY to the Water Line Installation.

