



Transmittal Form Chain of Custody New Main/Construction Water Quality Report

5 of 5

Wichita Public Works & Utilities
 Production and Pumping Division, 1800 Museum Blvd.
 Wichita Municipal Water & Wastewater Laboratory E-60603
 Phone # 316-269-4770/4771
 Fax # 316-269-4772

APPROVED BY: <u>Jc 2-28-19</u>
OF SAMPLES: <u>1</u> RECEIPT #: <u>122941</u>

Project Location: 10107 W York Contractor: Wilks Underground
 Project Number: 2175 PAW 2175 Contractor phone #: 316 640 4326
 OCA Number: 185009 Contractor fax #: _____
 Sample Collector: Chad Davis Contractor email: Chad@Wilksunderground.com

Items in gray are for Lab Use only

Date	Time	Description of Sample Location (line #, street, etc.)	Lab Log Number	Result Pass/Fail	Residual Cl ₂	Comment
5/30	12:01	Line 1	1520 1886	Fail	0.16	Low Chlorine

- **PLEASE RETURN EMPTY BOTTLES TO LABORATORY**
- **SEE SAMPLING INSTRUCTIONS ON THE BACK OF THIS FORM**

I, the sample collector, have followed the sampling protocol as written on the back of this form.

Sample collector signature: Chad Davis Date & time 5.30.19

CUSTODY RECORD	DATE	TIME		DATE	TIME
Relinquished by: <u>Chad Davis</u>	5/30	1:09 pm	Received by: <u>M. D. Bailey</u>	5/30	1:09 pm
Print Name:			Print Name: <u>Brooke Bailey</u>		
Relinquished by:			Received by:		
Print Name:			Print Name:		

Results Submitted by: Matt J Date: 5/31/19
 (over)