



GENERAL NOTES:

1. All Work To Be Performed In Accordance With The City of Wichita Storm Sewers & Drainage Standard Specifications.
2. All Concrete, Reinforcement, Removal, Labor, Excavation, And All Other Incidentals Shall Be Incidental To Concrete Drop Structure.
3. All Exposed Concrete Edges Shall Be Beveled 3/4".
4. All Reinforcing Steel To Have Minimum of 1-1/2" Concrete Cover.

