



F:\Projects\Projects 4700-4799\4701W (Rose Marie waterline replacement)\4701W Water Details-Part B.dwg

FIRE HYDRANTS REQUIRED				
Line No. - Street, Station	Bury Line Elevation	Top of Pipe Elevation	Hydrant Bury Required	Valve Stem Extension Required
Line 17 - Ida, 0+12.00	1283.47	1279.64	4.50	
Line 24 - Alturas, 7+45.00	1277.12	1273.29	4.50	
Line 25 - Catalina, 0+44.15	1279.20	1274.87	5.00	
Line 27 - Galena, 2+15.00	1282.27	1278.44	4.50	
Line 30 - Marion, 0+60.00	1282.92	1278.59	5.00	
Line 31 - Kansas, 2+75.00	1283.77	1279.94	4.50	
Line 32 - Rose Marie 0+72.00	1281.51	1277.68	4.50	
Line 33 - Mason 12+31.24	1282.94	1279.11	4.50	
Line 34 - Classen 0+73.00	1281.51	1277.68	4.50	
Line 35 - Minnesota 7+19.46	1283.60	1279.77	4.50	
Line 39 - Denker 5+00.00	1280.15	1276.32	4.50	

ROSE MARIE WATER - Part B Hydrant Table				
		GARVER 924 N. MAIN WICHITA, KS 67203 316-264-8008 WWW.GARVERUSA.COM		DATE 4/2/2018
		PROJECT NUMBER 448-90721	GARVER JOB NO. 16264701	DWG. SCALE ...
DRAWING FILE 4701W Water Details-Part B [Hydrant Table]			SHEET 3 OF 53	