

E PAWNEE AVE

LINE 2

INSTALL FIRE HYDRANT ASSEMBLY

①

②

AT&T

FH10015
V33340

V33341

8" PVC WL

PRIVATE WATER SERVICE LINES TO BE INSTALLED MUST MAINTAIN A MINIMUM OF A 10' HORIZONTAL CLEARANCE FROM EXISTING SANITARY SEWER MAINS AND MANHOLES. WHERE PRIVATE WATER SERVICE LINES CROSS SANITARY SEWER MAINS 25" OF VERTICAL CLEARANCE MUST BE MAINTAINED OR THE SANITARY SEWER LINE MUST BE ENCASED 10' ON EITHER SIDE OF THE CROSSING.

INSTALL 230 LF 8" PVC AND 20 LF DICL AND BENDS AS NEEDED TO CONNECT TO EXISTING LINE

CITY TO INSTALL 8"X8" TAPPING SLEEVE AND 8" GATE TAPPING VALVE (W) CONTRACTOR TO INSTALL CITY PROVIDED VALVE BOX

VERIFY THAT 2401 AND 2409 S ROOSEVELT ARE CONNECTED TO THE MAIN IN ROOSEVELT BEFORE ABANDONING THE LINE IN THE REAR. IF THEY ARE SERVED FROM THE REAR, INSTALL 2 NEW SERVICES AND CONNECT TO PAWNEE



PLANEVIEW WATERLINE REPLACEMENT LINE 2		
CITY ENGINEER GARY JANZEN, P.E.		
PROJECT NUMBER 448-2021- W7019	OCA NUMBER 637504 021884	DATE 07/2021
CITY ENGINEER'S OFFICE CITY HALL - SEVENTH FLOOR 455 NORTH MAIN STREET WICHITA, KANSAS 67202-1620 (316) 268-4501 (316) 268-4114 FAX		DESIGN GAL
		DRAWN DEA
		SHEET 6 OF 28

STEARMAN PARK



Evergy

KCS

AT&T

KCS

Evergy

6" SS

KCS

6" SS

KCS

6" SS

KCS

KCS

Evergy

KCS

Evergy

AT&T

Evergy

8" SS

8" SS

8" SS

8" PVC WL

S ROOSEVELT ST

3627
3629 (31)
E PAWNEE

3635
3637 (39)
E PAWNEE

2401 S
ROOSEVELT

2400/2404 S
ROOSEVELT

3805/
PA

3676/3680 E
CESSNA

2449 2453(55) S
ROOSEVELT

2425/2421 S
ROOSEVELT

2409 S
ROOSEVELT

2408 S
ROOSEVELT

3684/3688 E
CESSNA

3672/3668 E
CESSNA

2459/2463 S
ROOSEVELT

2413/2417 S
ROOSEVELT

3810

31.7

30'

30'

2.2

13.6

12.5

Evergy

50'

50'

50'