SCALE: 1"=20'

20' 0 20' 40'

(792) @ Sta. 1099+58.76, 40.01', Lt. =
Sta. 421+14.59, Waterline 2
Install 1 - 12" 11.25° Bend (Restrained)(E)
Install 142.77 LF 12" Pipe (E)
N 1,673,032.6370
E 1,636,285.0662

@ Sta. 1101+03.00, 16.08', Lt.
Remove 10.00 LF 12" Pipe (W)
Install 2 - 12" AC Transition Coupler (E,W)
Install 2 - 12" MJ Cap (E,W)
Abandon 12" Waterline in Place (W)
N 1,673,011.2562
E 1,636,429.7097

(795) @ Sta. 1101+01.52, 44.01', Lt. =
Sta. 422+57.36, Waterline 2
Install 1 - 12" 45° Bend (Restrained)(SE)
Install 11.95 LF 12" Pipe (SE)
N 1,673,035.1627
E 1,636,427.8110

(797) @ Sta. 1101+09.97, 31.56', Lt. =
Sta. 422+69.31, Waterline 2
Install 1 - 12" 45° Bend (Restrained)(S)
Install 19.44 LF 12" Pipe (S)
N 1,673,026.8624
E 1,636,436.4075

(798) @ Sta. 1101+10.00, 16.09', Lt. =
Sta. 422+84.78, Waterline 2
Install 1 - 12" Hot Tap with 12" Valve Assy. performed by the City of Wichita
Valve Box Elev. =
Contractor to Connect to 12" Valve (N)
N 1,673,011.3923
E 1,636,436.7084

Temp. Esmt.
Exist. R/W
W.V.
Exist. R/W
S. SHERIDAN STREET
POT+26.64
1100
1
2
PAWNEE STREET
3
4
@ Proposed Improvements = ℄
MATCHLINE STA. 1099+40.00
Exist. R/W
Temp. Esmt.
Exist. R/W
S. SHERIDAN STREET

TRANSYSTEMS
245 N. WACO
SUITE 222
WICHITA, KANSAS 67202
MAIN: 316-303-3000
FAX: 316-462-5629

MICHAEL D. BAILEY LICENSED 20585 8/15/2027 KANSAS PROFESSIONAL ENGINEER

CONSULTANTS:

WEST STREET IMPROVEMENTS
FROM PAWNEE TO HARRY

WICHITA, KANSAS

CITY OF WICHITA

REVISIONS:

MARK	DATE	DESCRIPTION

PROJ NO: 87 N-0720-01
SCALE: 1"=20'
DATE: 9/25/2023
DESIGNED BY: DAN
DRAWN BY: DAN
CHECKED BY: MDB

SHEET TITLE:

PAWNEE ST.
WATERLINE
IMPROVEMENTS

SHEET NO.
389

SHEET 389 OF 517

lcrahe
9/25/2023 - 6:48:11 PM - c:\transystems\cw_local\transyscorp-pw1\ae_lcrahe\d0984549\C-WTR-M02-105.DGN

IF THIS DRAWING IS LESS THAN 22" X 36" IT IS A REDUCED SIZE DRAWING