

GODDARD FACILITY IMPROVEMENTS
#1 - New Elementary School

GODDARD PUBLIC SCHOOLS U.S.D. No. 265
201 S. MAIN, GODDARD, KANSAS
SANITARY SEWER

CITY OF WICHITA PRIVATE PROJECT NO.1558PPS (607861)
JIM L. ARMOUR, P.E.-CITY ENGINEER

APPROVED AS NOTED
BY CITY ENGINEER OF WICHITA,
BY WICHITA WATER & SEWER DEPARTMENT,
& BY WICHITA FIRE DEPARTMENT

Water Mains (Pub Mks) _____
Water Mains (W & S) _____
Fire Prot. Line _____

NOTE TO CONTRACTORS

Public Property:
Inspection and testing for the waterline is to be provided by a Licensed Consulting Engineering Firm under contract with the Owner/Developer. Said inspection to be in accordance with the City of Wichita standard construction engineering practices and certified by a Professional Engineer Licensed in the state of Kansas. No work shall be performed in dedicated easements or public right-of-way by the Contractor until such inspection is arranged for and required bonds have been submitted and approved by the City nor shall any work be commenced without written authorization by the City Engineer. All Construction and Materials shall comply with the City or Wichita Specifications and Standards (on file and available in the City Engineer's Office).

Private Property:
Installation and testing for the fire protection line is to be performed by a City of Wichita licensed fire protection contractor in accordance with the fire codes as adopted by the City of Wichita. All material and construction practices for the fire protection line shall comply with the fire codes as adopted by the City of Wichita (available from the City of Wichita Fire Department). The Contractor shall not commence work without notification and approval of the Wichita Fire Department. Inspection of the fire protection line is to be provided by a licensed Engineering Firm under contract with the Owner/Developer and the Fire Department. The contractor shall not start work until the project inspector is assigned to the project and present on the site. Any work done without inspection will be required to be uncovered for inspection.

Improvements performed under this project may not be accepted by the City of Wichita until all applicable documentation has been submitted to the City Engineer. This may include: record drawings, inspection logs, test documentation, tv tapes, and a certificate of completion. The above shall be performed by the Consulting Firm contracted to inspect the project.

GENERAL NOTE:
PROVIDE ALL MATERIALS IN ACCORDANCE WITH
CITY OF WICHITA SPECIFICATIONS.



REVISION	DATE	BY
WILSON & COMPANY Engineers & Architects 1702 East 10th - Salina, Kansas 67401 Tel 785-827-0433 Fax 785-827-0949		
GODDARD FACILITY IMPROVEMENTS #1 - New Elementary School GODDARD PUBLIC SCHOOLS U.S.D. No. 265 201 S. MAIN, GODDARD, KANSAS		
DESIGN	JLL	
DRAWN	DFP	
DATE	MAY 2005	
FILE NO.	X4-420-078	
SHEET NO.	V01	